

CZECH TECHNICAL UNIVERSITY IN PRAGUE FACULTY OF CIVIL ENGINEERING – TEST LABORATORY Test laboratory No. 1048 accredited by ČIA according to

Test laboratory No. 1048 accredited by ČIA according to ČSN EN ISO/IEC 17025:2018







L 1048

1	CVDE	DT	TA	DOD	ATORY	Ω I	124
	EXPE	KI	1A	KUK	AIUKY		124

Phone: +420224354806 E-mail: jiranek@fsv.cvut.cz No. of copies: 2
Copy No: 1
No. of pages: 3

Page No.: 1
No. of annexes: 0
No. of annexes pages: 0

Order No:

8602148A000

TEST REPORT No: 124042/2021

upon the test: Determination of the radon diffusion coefficient of VOLTEX GB-500 membrane carried out in accordance with the ISO/TS 11665-13

Client's name and address:

CETCO Poland CETCO Sp. z o.o. S.K.A. Korpele 13A - Strefa 12-100 Szczytno Poland

Date of issue: 26.7.2021

Approved by:

SAL OPEN JUGORAN DE LA COMPANION DE LA COMPANI

prof. Ing. Martin Jiránek, CSc. head of OL 124 laboratory

This report can only be reproduced in its entirety; in part only with a written consent of the testing laboratory. The test results refer exclusively to the subject of the test (test sample).

CZECH TECHNICAL UNIVERSITY IN PRAGUE FACULTY OF CIVIL ENGINEERING – TEST LABORATORY Test laboratory No. 1048 accredited by ČIA

according to ČSN EN ISO/IEC 17025:2018

Thákurova 7, 166 29 Praha 6

Issue No.: 1
Page No.: 2

Report No: 124042/2021

Date of issue: 26.7.2021

Subject of the test: VOLTEX GB-500 - GB-500 multilayer polymeric membrane

integrally bonded to VOLTEX geomembrane

Testing procedure: Determination of the radon diffusion coefficient

Test regulation: ISO/TS 11665-13, method A **Test execution date:** 16.7.2021 – 23.7.2021

Test execution place: laboratory OL124 – D2044d

Test samples

Test samples were cut from the material handed by the client representative Łukasz Mikoda on 16.7.2021. The samples were registered with marks 29/21/J (1 to 3) by M. Jiránek. The dimensions of the samples were 135 x 325 mm (effective area 293.10⁻⁴ m²) and their thickness was 0,50 mm. As required by ISO/TS 11665-13, the permeable surface layers (VOLTEX geomembrane) shall be removed from the sample before testing. For this reason, the same samples as for the GB-500 membrane without geomembrane were used to determine the diffusion coefficient of VOLTEX GP-500.

Test method

Radon diffusion coefficient was determined according to the method A of ISO/TS 11665-13. The tested samples were placed between the source and the receiver containers. Radon diffuses through the samples from the source container, which is connected to the radon source RF 100, to the receiver containers. Concentrations on both sides of the tested samples are measured continuously by radon detectors TSR-4 of the TERA system (receiver containers) and current mode ionization chambers (source container). Radon diffusion coefficient was derived from the process of fitting the numerical solution to the curves of radon concentration measured in the receiver containers. Numerical solution is based on the one-dimensional time-dependent diffusion equation describing radon transport through the tested material.

Laboratory conditions

VOLTEX GB-500 - material

Steady state radon concentration in the source container: $4.6 \pm 0.1 \text{ MBq/m}^3$ Maximum radon concentration in the receiver containers: $0.4 \pm 0.1 \text{ kBq/m}^3$

Laboratory temperature: $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$

Relative humidity of air in the laboratory: $49\% \pm 3\%$

Pressure difference between the lower and the upper containers: 1 Pa \pm 1 Pa

CZECH TECHNICAL UNIVERSITY IN PRAGUE
FACULTY OF CIVIL ENGINEERING – TEST LABORATORY
Test laboratory No. 1048 accordited by ČLA

Test laboratory No. 1048 accredited by ČIA according to ČSN EN ISO/IEC 17025:2018

Thákurova 7, 166 29 Praha 6

Issue No.: \mathcal{A} Page No.: 3

Report No: 124042/2021

Date of issue: 26.7.2021

Test device

Radon detectors TSR-4 of the TERA system (N17) Measuring system with ionization chambers operating in current mode (N14) Radon concentration measuring system RM-2 (N15) Micrometer (N11)

Test results

The resulting values of the radon diffusion coefficient, the radon diffusion length and the radon resistance including expanded measurement uncertainty, are listed in the following table. The results refer to the samples as they were taken over.

TESTED MATERIAL	VOLTEX GB-500		
RN DIFFUSION	mean value	7,1.10 ⁻¹⁴	
COEFFICIENT D (m ² /s)	±U	± 0,8.10 ⁻¹⁴	
N DIFFUSION LENGTH	mean value	1,8.10-4	
<i>l</i> (m)	±U	± 0,2.10 ⁻⁴	
RN RESISTANCE R_{Rn}	mean value	19 557	
Ms/m)	±U	± 2 327	

The expanded uncertainties of measurement $\pm U$ mentioned are the product of standard measurement uncertainties and the expansion coefficient k=2, which provides a confidence interval of approx. 95 %. The radon diffusion length was calculated according to the equation $I=\sqrt{D/\lambda}$ and the radon resistance as follows: $R_{\rm Rn}=\frac{\sinh(d/l)}{\lambda \cdot l}$, where $\lambda=2,1.10^{-6}~{\rm s}^{-1}$ and $d=0,50~{\rm mm}=0,50.10^{-3}~{\rm m}$.

The test was performed by: prof. Ing. Martin Jiránek, CSc., Ing. Veronika Kačmaříková, Ph.D.

The report was prepared by: prof. Ing. Martin Jiránek, CSc.

end of the report