

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

—
VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

DEPARTMENT OF
BUILDING AND SAFETY

201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—
OSAMA YOUNAN, P.E.
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

CETCO
2870 Forbs Ave
Hoffman Estates, IL 60192

Attn: Building Materials
(847) 851-1800

RESEARCH REPORT: RR 25669
(CSI 07110)

Expires: June 1, 2022
Issued Date: June 1, 2020
Code: 2020 LABC

GENERAL APPROVAL– Renewal and Clerical Modification - Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System for Wall and Slab Waterproofing.

DETAILS

1. The above product is approved for below-grade waterproofing as required by Chapter 18 of the Los Angeles Building Code. The product may be used in conjunction with Los Angeles City approved caulking materials at penetrations of the waterproofing membrane.
2. The application of the material shall be in accordance with the manufacturer's instructions. A copy of the instruction shall be available at each job site.
3. The product shall be in full contact with the wall and soil at all times.
4. The maximum allowable hydrostatic pressure of the Straaseal HR is 64.5 psi.

RR 25669
Page 1 of 3

CETCO

Re: Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System

DISCUSSION

The report is in compliance with the 2020 Los Angeles City Building Code.

The clerical modification is to update this report to 2020 LABC.

The approval is based on tests.

Strataseal HR was tested with 129 psi Hydrostatic Resistance.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

DAVID CHANG, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

DC
RR25669
TLB2000096
R06/01/2020
1805.3

CETCO

Re: Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System